
Installation Guide | Lighting Fixture

Tracklight

MMP-080S/SH/1E/10B/Z2/3

FOR USE WITH EUTRAC CORP, Series 225, TRACK SYSTEM ONLY. EUTRAC lighting track is sold separately.




(1) Warning	Failure to ir	nstall t	he fixture properly could result in pers	sonal injury.	O:Pr	ohibited	
(1) Caution: Failure to install the fixture properly could result in property damage.						rict observance	
Before installation	1 Warning		The fixture is for indoor use only in general conditions. This fixture can only be installed on a horizontal ceiling. Can not be used following conditions (Causes of falling, electrocution and fire) Inclined, uneven surface Ambient temperature under 0°C and over 35°C High humidity Ceiling which can't hold the fixture weight Outside				
		\Diamond	•	es affected by wind or air	onditioner m	achine	
			Vibrated or shocked areas	•			
			●Areas get direct sunlight ●Dus	ty areas, corrosive ga	outbreaks	areas	
			Please contact if you are not able to environment is suitable to the place		stallation	n	
	Caution	0	Please follow the fixtures' indication or specification for the distance of irradiated area. (Causes of change in shape, change in color of irradiated objects)				
For electric wiring	1 Warning	0	Only qualified person may work on electric wiring and equipment. (Cause of accidents)				
		0	Use alternating current. Please follow rating plate of fixtures for power supply frequency. (Cause of electrification • fire) (50Hz • 60 Hz common use for ballasts and incandescent lamp fixtures)				
		0	Be sure power supply voltage is within $\pm 6^\circ$	% mentioned in rati	g plate or t	the guide. (Causes of short life of lamps • electrification • fire	
		0	Be sure all the wires and codes are r	ot damaged. (Ca	uses of fa	lling • damage)	
At lighting fixture installation	1 Warning	0	Please follow the fixtures' instruction of	r this guide to ins	all the fixt	ure and lamp. (Causes of falling • electrification • fire)	
		0	Switch off the power when installing	g the lamp. (Caus	es of elec	trification)	
		0	Do not touch the fixture when switch	h is on or just tu	n off the	switch because of high temperature.	
		0	Do not put or cover the fixture by ar	ny cloths, papers	or insulat	tors.(Causes of not lighting • fire)	
		0	Do not place any metallic or flamma	ıble objects. (Cau	se of elec	trification • fire • broken fixture)	
		0	Make sure to install all the parts of fixtures besides installation and mounting parts will not touch with any objects both inside and outside of ceiling such as lighting track, etc. (Causes of falling • electrification • fire)				
		0	Do not dismount or remodel fixture	s. (Cause of elect	ification	• fire • falling • broken fixtures)	
		0	Do not operate with wet hands.				
		0	If you smell smoke, see smoke, or find anything unusual, please turn the switch off and ask construction companies to repair. (Cause of electrification • fire)				
	(Caution	0	Make sure the construction will not affect any fire prevention systems such as sprinkler by heat from the fixture. (Causes for improper operation)				


ModuleX

Installation Guide Lighting Fixture

Tracklight To install ModuleX safety

MMP-080S/SH/1E/10B/Z2/3





(Contact)

Concord Lighting

5/F, Longbow House,14-20 Chiswell Street, London, EC1Y 4TW, UK Tel: +44-01273-616649

(Manufacturer)

ModuleX Inc.

#21 AraiBldg, 1-20-6 Ebisu-Minami Shibuya-ku, Tokyo Tel: +81-3-5768-3131